CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0026:177 Page 1 of 2

CATEGORY: Control Units/Non High Rise

LISTEE: Simplex, *100 Simplex Drive, Westminster, MA 01441-0001

Contact: Paul Mattern (978) 731-8542

DESIGN: Model 4002-8001 control unit. Power-limited; coded, non-coded or march time; local, local with

> shunt master box, auxiliary, remote station, (protected premises) and proprietary (protected premises) service; automatic, manual, waterflow alarm, sprinkler supervisory and releasing devices service. Refer to listee's data sheet for detailed product description and operational

considerations. Components:

4002-8901 Add-on expansion module

4002-6001, -6002 Power Input

4002-7001, 7002 CPU

4002-5001 thru -5004 Initiating module

4002-0121 Interface 4002-0110, -0111 Power Supply 4002-0113 Fan Control 4002-0115 **Battery Meter**

4002-0102 Zone Disconnect module 4002-0103, -0104, -0105 **Transient Suppression Module**

Dual Signal module 4002-4101 **Auxiliary Relays**

4002-3001, -3002, -3003 **ESP Programming Option** 4002-0112

***2081-9271,-9272,-9274,-9275** Batterv

4002-1010 **External Batteries** Coil Supervision module 2081-9032

Enclosure 4002-2001, -2002, -2003 2975-9184 thru -9189 Backbox

4009-9801, -9802 **External Battery Cabinet**

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model/catalog number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

> indicating devices and Model 2120 communications module (CSFM Listing No. 7170-0026:125 and 7165-0026:126). May include the use of Model 4601-9102 remote control annunciator.

This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) as required per NFPA 72, 1993 Edition. Refer to

manufacturer's Installation Manual for details.

*Rev. 06-06-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: FEBRUARY 6, 2001 Listing Expires June 30, 2002

Authorized By: **BEN HO**, Supervising Deputy

Program Manager